

NORTH BENGAL CHEMICAL TESTING AND ANALYSIS LAB (MICRO-DIVISION)

Registered Under Govt. of West Bengal, DIC Entrepreneur's Memorandum No. : 190012110563 dt. 09/10/2009.

Regd. Office: MaaKalyani Kali Bari, Gadadharsarani, P.O Rabindrasarani, Rabindranagar,
Siliguri, Pin--734006, Dist-Darjeeling, State-West Bengal, India. Phone: 97330-30549 / 94753-01359.
email.nbctslg09@gmail.com / siligurilab@gmail.com / mukherjeesoumen70@gmail.com,
Website: www. Northbengalchemicaltestingandanalysislab.siliguri.

Certificate for water Sample analysis

Name and address of client:

M/S. SRI KRISHNA PRANAMI VIDYA NIKETAN
SHIV MANDIR ROAD, SEVOKE ROAD,
HAIDERPARA, SILIGURI-734001 (W.B).

Analysis Report Number

NBCTAL /08/2017/02

RESULTS OF ANALYSIS

Sample Received on	Analysis Duration	Sample Description & Ref. of client's letter.	Quantity of Sample	Sample Submitted by
09/08/2017	09/08/2017 to 16/08/2017	Water Ref.No.SKPVN /2017-18/24, Dated-09/08/2017	1 x 1000ml (approx)	Drawn by Party (Sample will be destroyed by us after issuance of this certificate).

Table 1- Organoleptic, Physical & General Parameters:

Sl No.	Test parameters (Characteristic)	Method of test Ref to	Limit as per (IS:10500-2012)	Results Obtained
1.	Colour, Hazen units, Max	NBCTAL/DW (part 4):1983	5Hazen Units	2Hazen Units
2.	Odour	NBCTAL/DW (part 5):1983	Agreeable	Agreeable
3.	pH value	NBCTAL/DW (part 11) :1996	6.5 to 8.5	6.9
4.	Taste	NBCTAL/DW (part 7 & 8)	Agreeable	Agreeable
5.	Turbidity, NTU, Max	NBCTAL/DW (part 10) :1984	1 NTU	1 NTU
6.	Total Dissolved solids(TDS), mg/l, Max	NBCTAL/DW (part 16) :1984	500 mg/l,Max.	68 mg/l
7.	Aluminium(as Al), mg/l, Max	NBCTAL/DW (part 55):2003	0.03 mg/1, Max	Nil
8.	Calcium (as Ca), mg/l, Max	NBCTAL/DW (part 40):2003	75 mg/1, Max	07 mg/1
9.	Chloride (as Cl), mg/l, Max	NBCTAL/DW (part 32): 2003	250 mg/1, Max	10 mg/1
10.	Copper (as Cu), mg/l, Max	NBCTAL/DW (Part 42) : 1964	0.05 mg/l,Max	Nil
11.	Total Alkalinity (as CaCO ₃), mg/l, Max	NBCTAL/DW (part 23):2003	200 mg/1, Max	56 mg/1
12.	Total hardness (as CaCO ₃),mg/l, Max	NBCTAL/DW (part 21) : 2009	200 mg/l,Max.	34 mg/l
13.	Iron (as Fe), mg/l, Max	NBCTAL/DW (part 53): 2003	0.3 mg/l,Max.	0.28 mg/l
14.	Barium(asB),mg/l,Max	NBCTAL/DW Annex F of IS 13428:2005	0.7 mg/1, Max	Nil
15.	Manganese(as Mn), mg/l, Max	NBCTAL/DW (part 59) : 2006	0.10 mg/l,Max.	Nil
16.	Magnesium (as Mg), mg/l Max.	NBCTAL/DW (part 46): 1994	30 mg/1, Max	01 mg/1
17.	Nitrate (as No ₃), mg/l, Max	NBCTAL/DW (part 34): 1988	45 mg/l,Max.	Nil
18.	Sulphate (as SO ₄), mg/l, Max	NBCTAL/DW (part 24):2003	200 mg/1, Max	15.0 mg/1
19.	Sulphide(as H ₂ S) , mg/l, Max	NBCTAL/DW (part 29):1992	0.05 mg/1, Max	Nil
20.	Residual free Chlorine, mg/l, Min.	NBCTAL/DW (part 26): 2003	0.2 mg/l, Min.	Nil
21.	Zinc (as Zn) mg/l, Max	NBCTAL/DW (Part 49) :1994	5 mg/1, Max	Nil

Date of Issue : 16/08/2017

S. Kalisi
(Checked by)

For N.B.C.T.A.L

S. Mukherjee

(Authorised Signatory)

NOTES:

- The results given above are related to the tested sample, as received & mentioned parameters, the customer asked for the above tests only.
- In case of lack of correlation due to technical/typing error, the laboratory should be informed immediately for rectification/ review / resampling and retesting etc.
- This test report will not be generated again, either wholly or in part, without permission of the Laboratory.
- Contents of this report are meant for your guidance and should not be used for advertisements, evidence or litigation.
- Responsibility of the Laboratory is limited to the invoiced amount only.

-----End of Report-----

[Signature]
PRINCIPAL

Sri Krishna Pranami Vidya Niketan
Affiliated To C.B.S.E. Code -2430103
Haiderpara-Siliguri

[Signature]
Manager

Sri Krishna Pranami Vidya Niketan
Siliguri - 734001

SILIGURI MUNICIPAL CORPORATION

NO. SILIGURI, DIST. DARJEELING (W.B.) PHONE : 2432804, 2435444 (FAX), 2433277

Memo No: 24 /SMC/CONV./'17-'18

Date: 16.1.18/2017



TO WHOM IT MAY CONCERN

This is to certify that Sri Krishna Pranami Vidya Niketan located at Shiv Mandir Road, Haiderpara, Ward No. 40 (Borough -V) under CBSE Board have possessed proper sanitary system in the school and is found to be satisfactory as per the inspection report of Sri Salil Sarkar, Sanitary Inspector, Siliguri Municipal Corporation.

[Signature]
Commissioner

Siliguri Municipal Corporation

[Signature]

PRINCIPAL

Sri Krishna Pranami Vidya Niketan
Affiliated To C.B.S.E. Code -2430103
Haiderpara-Siliguri

[Signature]

Manager

Sri Krishna Pranami Vidya Niketan
Siliguri - 734001