



सत्यमेव जयते

Government Of West Bengal
Office Of The Divisional Fire Officer, Darjeeling
West Bengal Fire & Emergency Services
Station Feeder Road, P.O & P.S Siliguri,
District: Darjeeling, Pin - 734005

Memo no.: IND/WB/FES/20192020/77450

Date: 14-02-2023

From:
Divisional Fire Officer, Darjeeling
West Bengal Fire & Emergency Services

To:
Shree Krishna Pranami Vidya Niketan
Haider Para, Siliguri, Jalpaiguri
Jalpaiguri F. S., Bhaktinnagar
Jalpaiguri - 734001

Sub: Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 1 Storied building under group Educational at the Premises No. Shree Krishna Pranami Vidya Niketan, Haider Para, Siliguri, Jalpaiguri, Bhaktinnagar, Jalpaiguri - 734001

This is in reference to your application no. IND/WB/FES/20192020/77450 dated 14-02-2023 regarding Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 1 Storied building under group Educational at the Premises No. Shree Krishna Pranami Vidya Niketan, Haider Para, Siliguri, Jalpaiguri, Bhaktinnagar, Jalpaiguri - 734001

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

PRINCIPAL

Sri Krishna Pranami Vidya Niketan
Affiliated To C.B.S.E. Code -2430103
Haiderpara-Siliguri

Manager

Sri Krishna Pranami Vidya Niketan
Siliguri - 734001

- 1) Regular checking, testing and maintenance of fire safety systems/installations are must.
- 2) Good housekeeping to be maintained.
- 3) Regular checking and maintenance of electrical wiring and installation by licensed Electricians is must.
- 4) Regular mock fire drill and evacuation drill should be conducted by participation of all and for this purpose a special crew should be formed.
- 5) Certificate shall have to be obtained from this Office on routine basis about the satisfactory performances off all the fire and life safety installations failing which the Fire Safety Certificate shall be revoked as per rule 18 of the W.B. fire Services (Fire Prevention & Fire Safety) Rules, 2003.
- 6) Fire License shall be obtained from this department separately which are attracts section 12 of FS Act.
- 7) This certificate needs to be renewed after 3(three) yrs as per notification subject to ensure safety first and all safety measures should be in working condition at all time failing which this certificate will automatically liable to be cancelled.

Occupancy of the building shall not be allowed to change without the concurrence of this department and floor area, height etc. shall not be permissible to enhance without the concurrence of this department. No addition or alteration should be allowed without the prior approval of this department

9) Auto panel, pumps and all safety measures should be in working condition at all time and if any defects or if found the safety measures are not in working condition or if found exit /escape routes is compromised or not available as per the rules then this certificate will automatically liable to be cancelled in the life safety point of view or it will be revoked in the same causes.

10) All corridor, path and driveway to be free from all obstruction. Two staircases to be available in the mercantile area if any and sufficient ventilation to be provided in the basement area. Basement shall not be used for storage its only for parking.

IND/WB/FES/20192020/77450

?

Signature Not Verified

Digitally Signed
Name: PRODIP SARKAR
Date: 14-Feb-2023 18:31:15
Reason: Approved
Location: West Bengal

Divisional Fire Officer, Darjeeling
West Bengal Fire & Emergency Services



PRINCIPAL
Sri Krishna Pranami Vidya Niketan
Affiliated To C.B.S.E. Code -2430103
Haiderpara-Siliguri



Manager
Sri Krishna Pranami Vidya Niketan
Siliguri - 734001